







Pre-Task	<ul style="list-style-type: none"> • Consider the task and follow safe job procedures, industry best practices, and legislative requirements. • Complete a hazard assessment and follow controls. • Ensure that all equipment and circuits are designed and operated in accordance with the Canadian Electrical Code. • Obtain and follow the requirements of the permit. • Confirm specific power requirements (amperage and voltage).
During	<ul style="list-style-type: none"> • Shut off power whenever possible. • Electrical installations should only be completed by competent individuals. • Two or more competent individuals should team up on any energized circuit at or above 480 volts. • If ladders are required use nonconductive. • Remove panel covers with care, ensuring cover screws or panel fillers are removed. • Ensure other workers in the area are aware of the work being conducted and do not have access to the equipment while work is being done.
Post-task	<ul style="list-style-type: none"> • Never leave live equipment unsupervised. • Replace panel covers when complete. • Confirm that the electrical appliance or equipment is in good working condition.

Task/Environment/Equipment	
Live Electrical Equipment (working on live equipment)	
Protective Measures	
SSHA	
Engineering	
Training	
SJP	
ERP	
PPE	

The information presented in this publication is intended for general use and may not apply to every circumstance. It is not a definitive guide to OHS legislation or industry standards. This does not relieve persons using this publication from their responsibilities under applicable legislation. The Alberta Construction Safety Association does not guarantee the accuracy of, nor assume liability for, the information presented here.

Icons from The Noun Project: *warning-clipboard* by Suncheli Project, *secure* by Markus, *training* by Musmellow, *checklist* by Vectors Market, *agenda* by Rflor, *safety glasses* by André Renault