







Pre-Task	<ul style="list-style-type: none"> • Consider the task and follow safe job procedures, industry best practices, and legislative requirements. • Complete a hazard assessment and site inspection and follow the required controls. Only charge in a well-ventilated area. • Batteries contain sulphuric acid. Use all appropriate PPE. • Confirm location of the safety shower and other emergency response equipment that may be required.
During	<ul style="list-style-type: none"> • Only charge in a well-ventilated and secure location. • Ensure the charger is off before connecting the charging clamps to the battery. • Confirm that the charger's settings are appropriate for the battery being charged. • Use a cable clamp puller to remove the clamp from the battery. • Clean corrosion from battery posts using a taper brush. • Clean battery surface and dispose of rags appropriately. • Only use distilled water and never overfill battery.
Post-task	<ul style="list-style-type: none"> • Replace worn or unserviceable parts before reconnecting the battery. • Clean up any contaminated area and dispose accordingly. • Remove any contaminated clothing or PPE. • Wash hands after job completion.

Task/Environment/Equipment	
Batteries (charging and servicing)	
Protective Measures	
SSHA	
Engineering	
Training	
SJP	
ERP	
PPE	

The information presented in this publication is intended for general use and may not apply to every circumstance. It is not a definitive guide to OHS legislation or industry standards. This does not relieve persons using this publication from their responsibilities under applicable legislation. The Alberta Construction Safety Association does not guarantee the accuracy of, nor assume liability for, the information presented here.