







Pre-Task	<ul style="list-style-type: none"> <li>• Consider the task and follow safe job procedures, industry best practices, and legislative requirements.</li> <li>• Portable fire extinguishers must be installed, inspected, and maintained on a regular basis to ensure proper operation in an emergency.</li> <li>• Inspect and maintain as per manufacturer's recommendations.</li> <li>• Install as per fire code and local authorities' requirements.</li> <li>• Maintain a site map showing a detailed plan of the location for each fire extinguisher and other emergency response items.</li> </ul>
During	<ul style="list-style-type: none"> <li>• Visually inspect the cylinder for signs of damage.</li> <li>• Inspect cartridge puncture cap.</li> <li>• With the cartridge removed, check action of the puncture lever.</li> <li>• Check hose and nozzle for obstructions.</li> <li>• Check the date of manufacturer.</li> <li>• Check the level and condition of the powder.</li> <li>• Check the fill cap threads and gasket.</li> <li>• Attach the visual seal and check the pressure gauge.</li> </ul>
Post-task	<ul style="list-style-type: none"> <li>• Replace serviced extinguisher in designated location.</li> <li>• Document the inspection and service date.</li> </ul>

Task/Environment/Equipment	
<h3 style="margin: 0;">Inspecting Portable Fire Extinguishers</h3>	
Protective Measures	
SSHA	
Engineering	
Training	
SJP	
ERP	
PPE	

The information presented in this publication is intended for general use and may not apply to every circumstance. It is not a definitive guide to OHS legislation or industry standards. This does not relieve persons using this publication from their responsibilities under applicable legislation. The Alberta Construction Safety Association does not guarantee the accuracy of, nor assume liability for, the information presented here.